



Disneyr

Fire Enterprises Pvt.Ltd.

LICENSED FROM
Govt. of Maharashtra
Directorate of Maharashtra
Fire Services
**To act as Licensed Agency
for the Purposes of
Fire Prevention & Life Safety
Measures Act, 2006**

FORM B

[See section 3(3) and rule 4(2)]

**Six Monthly Certificate for January 2026
for compliance of the
Fire Prevention and Life Safety Measures.**

CERTIFICATE

Certified that I / We have carried out inspection of the Fire Prevention & Life Safety Measures installed in the following Building or Premises, namely :-

**AYURVED SHIKSHAN MANDAL'S
DHARMARTH ASHTANG AYURVED HOSPITAL**
2032/B/2, House No. 2062,
Sadashiv Peth, Pune - 411030
Wing : " B " (Gr. + 3 Floors)

I / We further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the Period **01-Jul-2025 to 31-Dec-2025** as required under the provisions of the - **Maharashtra Fire Prevention and Life Safety Measures Act, 2006** (Mah. III of 2007). The details of the Inspection & Maintenance of installations carried out by me / us are mentioned in the report appended herewith.

Place : Pune

Date : 10.02.2026

Signature



NEELKANTH
VASUDEO
DATAR

Digitally signed by
NEELKANTH
VASUDEO DATAR
Date: 2026.02.10
18:17:32 +05'30'

Copy to:

- Owner /Occupier of the Bldg./Premises
- Chief Fire Officer of the Local Authority
- The Director of Maharashtra Fire Services
- Office Copy

DISNYR FIRE ENTERPRISES PVT. LTD.

1094, Sadashiv Peth, Raghunath Chambers,
Bajirao Road, Pune - 411 030.
Tel. No. : 24477553/ 24430342 / 7066223388
Email : disnyr.fire@gmail.com
disnyrfireiv@gmail.com

Encl. : Inspection / Compliance Report

CORPORATE OFFICE :

1094, Sadashiv Peth, Raghunath Chambers, Opp. Janata Sahakari Bank Ltd., Bajirao Road, Pune 411 030.
Tel.: (020) 2447 7553/ 2443 0342/ 7066223388 Email: disnyr.fire@gmail.com / disnyrfireiv@gmail.com

www.disnyrfire.com

REGD. OFFICE :

1070, Sadashiv Peth,
Ramdoot Society, Pune 411 030.

Disnyr

Fire Enterprises Pvt.Ltd.

INSPECTION / COMPLIANCE REPORT FOR :- JANUARY 2026

AYURVED SHIKSHAN MANDAL'S DHARMARTH ASHTANG AYURVED HOSPITAL

2032/B/2, House No. 2062, Sadashiv Peth,
Pune - 411030

Wing : " B " (Gr. + 3 Floors)

Inspected on: 29.01.2026

Sr.	Equipment	Total Qty.	Remarks
[I]	WET RISER / DOWN COMER SYSTEM :- 1 No.		As per our Survey Report Missing Items Replacd Unserviceable Items - Serviced And Reqd. Repairs + Actions Taken.
1	Pipeline		
2	Butterfly Valve at Terrace Lvl.	1 No.	
3	NRV at Terrace Lvl.	1 No.	
4	Booster Pump - 3 HP Cap. with Starter & Cover	1 No.	
5	Fire Service Inlet	1 No.	
6	Single Outlet Fire Hydt. Valve : ISI Mark	4 Nos.	
7	Hose Box : Double	4 Nos.	
8	Delivery Hose - 15 Mtrs. with Male / Female Couplings	8 Nos.	
9	Short Branch	4 Nos.	
10	Hose Reel with Shut off nozzle & Rubber Hose	3 Nos.	
11	Fire Extinguishers ABC Stored Pressure type 4.0 Kg.	5 Nos.	Ensured Satisfactory Working of the System.
[II]	P. A. FIRE ALARM WITH TALK BACK SYSTEM :- 1 No.		
1	4 Zone Fire Alarm Panel	1 No.	
2	P. A. System	1 No.	
a	Manual Call Points	4 Nos.	
b	Speaker	1 No.	
c	Siren	1 No.	
3	Talk Back System	1 No.	
a	Microphone	1 No.	

NOTE:

**Training in System Operation - Imparted to Security Personnel ,
Staff Members & Occupiers.**

Occupiers advised to carry out -

- Daily checks of Fire Protection Systems & Equipment.**
- Trials Every Month & Report to us for any malfunctioning.**

NEELKANTH VASUDEO
DATAR

Digitally signed by NEELKANTH
VASUDEO DATAR
Date: 2026.02.10 18:21:52 +05'30'

FOR DISNYR FIRE ENTERPRISES PVT.LTD.

TRUE COPY
PRINCIPAL
ASHTANG AYURVED COLLEGE
PUNE-411030.

TRUE COPY
ASHTANG AYURVED COLLEGE
PRINCIPAL
PRINCIPAL
ASHTANG AYURVED COLLEGE
TRUE COPY